Limestone District School Board Ventilation Report September 2022								
Name of School Facility	Type of School Facility Ventilation	Ventilation assessed	Running ventilation systems longer	Higher grade filters installed	Increased frequency of filter changes	Increased fresh air intake (windows and/or mechanical ventilation systems)	HEPA units deployed in portables, as needed	Standalone HEPA filter units in place
Amherst Island	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	NA	Yes	NA	7
Amherstview	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	Yes	46
Bath PS	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	7
Bayridge PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	24
Bayridge SS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	41
Cataraqui Woods ES	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	Yes	21
Centennial PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	17
Central PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	NA	Yes	NA	17
Centreville PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	7
Clarendon Central PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	Yes	6
Collins Bay PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	14
École Maple ES	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	10
Elginburg & District PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	17
Enterprise PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	10
Ernestown SS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	61
Fairfield ES	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	23
Frontenac SS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	77
Glenburnie PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	16
Granite Ridge Education Centre (Elem)	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	2
Harrowsmith PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	Yes	25
James R Henderson PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	42
John Graves Simcoe PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	20
Joyceville PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	26
Kingston Secondary School	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	0
La Salle SS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	51
Lancaster Drive PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	Yes	23
Land O Lakes PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	12
Limestone Education Centre	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	23
Lord Strathcona PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	17
Loughborough PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	35
Loyalist C & VI (Sec)	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	76
Marysville PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	NA	Yes	NA	4
Molly Brant Elementary School	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Napanee DSS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	81
Newburgh PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	13
North Addington Education Centre (Elem)	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	42
Odessa PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	25
Perth Road PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	Yes	20
Polson Park PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	Yes	14
Prince Charles PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	18
Queen Elizabeth C&I holding	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	0
R Gordon Sinclair Memorial PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	20
Rideau Heights PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	29
Rideau PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	30
Selby PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	16
Southview Public School	Mechanical Ventilation	Yes	Yes	Yes	Yes	Yes	NA	6
Storrington PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	Yes	16
Sydenham HS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	Yes	72
Sydenham PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	10
Tamworth PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	NA	17
The Prince Charles S	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	36
Truedell PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	Yes	18
W. J. Holsgrove PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	16
Welborne Avenue PS	Mechanical Ventilation	Yes	Yes	No	Yes	Yes	Yes	30
Winston Churchill PS	Non-Mechanical Ventilation (Natural Ventilation / Exhaust Only)	Yes	Yes	NA	Yes	Yes	NA	19
								1331